



LOCATION OF FIRE BARRIERS, SEE DETAILS  
AA20(2)28, 31, 46, 47, 48, 49 AND AA20(22)20

60MIN FIRE RATED CONSTRUCTION

30MIN FIRE RATED CONSTRUCTION

FD30S - 30MIN RATED FIRE DOOR WITH SELF CLOSER AND SMOKE SEAL.

FD60S - 60MIN RATED PROPRIETARY PLASTERBOARD ACCESS PANEL WITH SMOKE SEAL TO BE KEPT LOCKED.

FD30 - 30MIN RATED HINGED ACCESS PANEL, TO BE KEPT LOCKED. NO SMOKE SEAL.

FD30 - 30MIN RATED FIRE DOOR, NO SMOKE SEAL. THESE DOORS MAY NOT REQUIRE SELF CLOSERS, AS ADVISED IN THE NEW PART B OF THE BUILDING REGULATIONS. TO BE CONFIRMED BY BUILDING CONTROL.

#### FIRE DETECTION AND ALARM:

ALL APARTMENTS TO BE PROVIDED WITH A MAINS POWERED DETECTION / ALARM SYSTEM IN ACCORDANCE WITH BS5839: PART 6 TYPE LD3 CONSISTING OF SMOKE DETECTORS IN ALL CIRCULATION SPACES (INTER-LINKED WITHIN THE APARTMENT. THE OPERATION OF ONE DETECTOR WILL CAUSE ONLY DETECTORS WITHIN THAT APARTMENT TO GO INTO ALARM.

THE DUPLEX APARTMENTS ARE TO BE PROVIDED WITH A MAINS POWERED DETECTION / ALARM SYSTEM IN ACCORDANCE WITH BS5839: PART 6 TYPE LD1 CONSISTING OF SMOKE DETECTION IN ALL AREAS OF THE APARTMENT. THE DETECTORS SHOULD BE INTER-LINKED WITHIN THE APARTMENT AND THE OPERATION OF ONE DETECTOR WILL CAUSE ALL THE DETECTORS WITHIN THE DUPLEX TO GO INTO ALARM.

THE RESTAURANT/COMMERCIAL AREA AND UNDERCROFT CAR PARK WILL BE PROVIDED WITH A CATEGORY M SYSTEM IN ACCORDANCE WITH BS5839: PART 1. THERE WILL BE NO INTERCONNECTION BETWEEN THESE AREAS AND THE RESIDENTIAL, HOWEVER THEY WILL BE LINKED TO EACH OTHER TO ALLOW FOR SIMULTANEOUS EVACUATION OF THESE AREAS.

FOR DETAILED LAYOUTS OF FIRE DETECTION AND ALARM EQUIPMENT REFER TO THE RELEVANT EDCM DRAWINGS.

#### EMERGENCY LIGHTING AND EXIT SIGNAGE:

EMERGENCY LIGHTING AND EXIT SIGNAGE WILL BE PROVIDED IN ALL ESCAPE ROUTES AND COMMON CIRCULATION AREAS IN ACCORDANCE WITH BS5266 PART 1: 1988 AND BS5499: PART 1 RESPECTIVELY.

FOR DETAILED LAYOUTS OF EMERGENCY LIGHTING AND EXIT SIGNAGE REFER TO THE RELEVANT EDCM DRAWINGS.

FOR MORE DETAILED INFORMATION REGARDING THE FIRE STRATEGY REFER TO ARUPFIRE'S FIRE SAFETY STRATEGY REPORT.

Rev	Date	Drawn	Checked	Rev	Date
24.04.07	FIRST ISSUE	NBr	RW		
A 26.04.07	60MIN FIRE RATED CONSTRUCTION SHOWN ADJACENT TO CENTRAL STAIR AND ESCAPE STAIR AFTER CONSULTATION WITH ARUPFIRE. DOOR FROM CENTRAL STAIR REQUIRED TO BE FD30S	NBr	RW		
B 17.08.07	CAVITY BARRIER LOCATIONS INDICATED	JD	NBr		
C 08.09.08	AS BUILT ISSUE	NBr	RW		

Drawn	Checked	Rev	Date

Drawn	Checked	Rev	Date

Drawing Status	Job No.	Drawing No.	Rev
AS BUILT	1864	AL20(68) 010	C
Job Title	© Drawing and design copyright of: * <b>FaulknerBrowns</b> Architects		
Drawing Title	Dobson House Northumbrian Way Killingworth Newcastle upon Tyne NE12 6QW. Telephone 0191 268 3007 Fax 0191 268 5227		
Date	Scale	Drawn	Checked
24.04.07	1:200@A3	NBr	RW

Do NOT scale this drawing  
Do not derive dimensions from digital media